HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month JANUARY-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	542	542	542	348	918	348	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

4/2/2022

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

4/2/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD
Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB
For the month FEBRUARY-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	918	542	348	345	918	1609	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Nil	Nil	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month MARCH-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	1609	1609	345	348	1609	348	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

19/4/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

19/4/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month APRIL-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	1609	918	542	348	918	348	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

18/5/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

18/5/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month MAY-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	1609	918	348	542	1609	348	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

8/6/2022

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

8/6/2022

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month JUNE-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	918	918	542	348	918	348	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

22/7/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

22/7/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month July-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	918	918	542	542	918	542	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Present	Present	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month August-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 10500 -2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	1609	918	348	542	1609	542	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	**NIL**

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

24/9/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

24/9/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD
Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB
For the month September-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 1050(-2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	918	918	542	918	1609	348	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Present	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

3/10/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

3/10/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.

HYDERABAD METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

Quality Assurance and Testing Wing, A F Beds,

Bacteriological Examination report of Drinking Water Sources of HMWS&SB

For the month October-2022

S No	Parameter	Raw water						Treated water						Limits as per IS 1050(-2012
		Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	Osman Sagar	Himayath Sagar	Singur	Manjira	Krishna	Godavari	
1	Total MPN count of Coliform Bacteria per 100 ml	2400	1609	542	542	918	348	Nil	Nil	Nil	Nil	Nil	Nil	NIL
2	E.Coli per 100 ml	Present	Nil	Nil	Nil	Present	Nil	Nil	Nil	Nil	Nil	Nil	Nil	NIL

Remarks: The bacteriological quality of the treated water is found to be adhering to drinking water standards.

18/11/22

Technical Officer (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

18/11/22

Dy. General Manager (QAT)
Central Lab, QAT Wing,
A.F Beds, Hyderabad.

General Manager (QAT)
QAT Wing, A.F Beds
HMWS&SB, Hyderabad.